

NOTE: FIELD REMOVE FOAM AND LINER AT CUTBACK.

FIELD-FILL W/ COMPRESSIBLE INSULATION
(NOT BY IMP SUPPLIER)

"GS-02S" GUTTER HANGER
20" O/C W/ (5) 1/4 - 14 x 0.88"
HWH DP1

SR_INSIDE
CLOSURE STRIP W/
3/4" x 3/32" BUTYL
TAPE SEALANT AT
TOP & BOTTOM

"GT_S"
GUTTER TRIM

1/4 - 14 x 0.88" HWH DP1 6" O/C

"BB-01" BIRD BLOCK W/

1/4 - 14 x 0.88" HWH DP1 12" O/C

"WC-01" PANEL CLIP W/
() 1/4 - 14 x HWH DP3 W/O
WASHER AT PANEL JOINT

BUTYL SEALANT AT
VERTICAL JOINT

EAVE STRUT
(NOT BY IMP SUPPLIER)

3"

1"

BUTYL TAPE
SEALANT STRIP
UNDER GUTTER
STRAP

SR_ ROOF PANEL CLIP W/
() 1/4 - 14 x 2" HWH DP3 W/O WASHER,
PER CLIP, PER PANEL AT EAVE STRUT


BUTYL TAPE SEALANT

BUTYL TAPE SEALANT (MARRY
TO VERTICAL SEALANT)

NOTE: DO NOT OVER-DRIVE FASTENERS. IF THE METAL AT THE EDGE OF THE PANEL IS DEFORMED OUT OF PLANE, THE ADJACENT PANEL WILL BE DIFFICULT TO ENGAGE AND WILL NOT SEAM. AFTER SR CLIP HAS BEEN INSTALLED OVER MALE LEG OF STANDING SEAM PANEL, PRE-CRIMP, USING 1/2" HAND CRIMPING TOOL.

EAVE W/ GUTTER

(SECTION VIEW)



DETAIL: **EAVE WITH GUTTER**

929 ALDRIDGE ROAD
VACAVILLE, CA 95688
TEL: (707) 359-2280
FAX: (707) 359-2286
WWW.AWIPANELS.COM

All Weather
Insulated Panels



APPLICATION:
SR ROOF, COMMERCIAL & INDUSTRIAL
AWIP DETAIL NUMBER:

DATE: 08/23/24
DRAWN BY: MMF

SHEET: 1 OF 1